



**LIGHT
LABORATORY
INC.**



SUSTAINING
MEMBER

www.lightlaboratory.com

Company Name:	Primus Lighting Inc.
Contact Name:	Jaime Calderon
Contact Number:	(626) 442-4600
E-MAIL:	jaime@primuslighting.com

Test Summary

File No.	Catalog Number	Description	Test Voltage	SKU	Report Type	Total Lumens	Wattage	Efficacy
L041507501	ALX3-DR-LED-H-35K-WAR	48"L. X 5"W. X 3"H. LED LUMINAIRE, WHITE TEXTURED ACRYLIC LENS	120VAC	401	Indoor	3550.05	48.47	73.24
L041507502	ALX3-DR-LED-H-35K-PARD	48"L. X 5"W. X 3"H. LED LUMINAIRE, PERFORATED ALUMINUM WITH WHITE ACRYLIC DIFFUSER	120VAC	401	Indoor	1893.57	48.42	39.11

* LED Indoor Report includes LM-79 report, report summary, candela array, Zonal Lumen, CU table, Polar curves.

* LED Outdoor Report includes LM-79 report, report summary, candela array, CU graph, Polar curves, Isolines and LCS graph.

* LED Flood Report includes LM-79 report, report summary, Axial Display, Isocandela.